

**CITY OF MIDDLETOWN
PURCHASING DEPARTMENT**

ADDENDUM #1 TO BID #2013-001

Painting of Process Piping at the John S. Roth Water Treatment Plant

Date Issued: April 25, 2013

ALL BIDDERS ARE HEREBY ADVISED OF THE FOLLOWING AMENDMENTS TO THE CONTRACT BID DOCUMENTS:

THE BID HAS BEEN MODIFIED IN THE FOLLOWING AREAS:

Clarification of QP1 certification.

Section 09900-14 3.05 Surface Preparation

INVITATION TO BID

The date set for the receipt of proposals will remain the same.

*****Thursday, May 2, 2013 at 11:00 AM*****

PLEASE VERIFY THAT YOU HAVE RECEIVED THIS NOTIFICATION IN THE SPACE BELOW AND FAX OR EMAIL THIS PAGE BACK TO THE PURCHASING DEPARTMENT.

FAX: 860-638-1995

EMAIL: purchase@middletownct.gov

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM #1: _____

COMPANY NAME

All bidders are hereby advised of the following amendments to the contract bid documents which are hereby made an integral part of the specifications for the subject project, prepared by the City of Middletown to the same extent as all other documents. All work shall conform to the standards and provisions of same. Bids submitted shall be deemed to include contract document information as shown in Addendum No. 1. General bidders shall notify sub-bidders that may be affected by this addendum as applicable. **Bidders shall be required to acknowledge receipt of this addendum in the space provided on the Bid Proposal Form on Pg. 34.**

Failure to acknowledge receipt of this addendum by the bidder may result in the rejection of their bid. Bidders are directed to review changes to all portions of the work as changes to one portion may affect the work of another.

TOTAL ADDENDA 2 PAGES

*****BIDDER NOTE:** If you have already submitted a bid you shall be required to acknowledge receipt of this addendum under separate cover in a sealed envelope clearly marked with the bid number and description. This acknowledgment must be received by the time and date specified to be accepted by the City

Donna L. Imme, CPPB
Supervisor of Purchases

APRIL 25, 2013

CITY OF MIDDLETOWN WATER AND SEWER DEPARTMENT
MIDDLETOWN, CONNECTICUT

CONTRACT DOCUMENTS
BID # 2013-001

PAINTING OF PROCESS PIPING
AT THE JOHN S. ROTH WATER TREATMENT PLANT

ADDENDUM NO. 1.

The following additions and/or alterations to the contract documents for the above referenced contract are to be incorporated into all general bids for the proposed work.

Inclusion of this Addendum must be acknowledged by inserting the addendum number and date in the specification section entitled "Bid Proposal Page". Failure to acknowledge any and all addenda in the above specified specification section may be cause for rejection of the bid by the OWNER on the grounds that it is not responsive to the "INFORMATION FOR BIDDERS".

PRE-BID CONFERENCE MEETING MINUTES ARE POSTED TO OUR WEBSITE

QPI certification is not necessary for this project.

The following revisions and/or additions shall be made to the Contract Documents:

INFORMATION FOR BIDDERS

In reference to Section 09900-14 3.05 SURFACE PREPARATION:

Delete paragraph 3.05.A.1 and replace it with the following:

- 1. All piping will be high pressure water blasted to remove weak paint and loose corrosion products. Water pressure is to be 4,000 to 5,000 psi. After water blasting all rusting areas should be power tool cleaned to bare metal SSPC-SP11 standard. There are to be no loose paint edges. All paint debris must be collected and properly disposed of. All solid intact coating on the pipes shall be abraded to remove gloss or shine to accept a new overcoat application. Abrasion can be accomplished by hand sanding or disc sanding. Localized containment or dust controls must be in place to control dust generated during these activities.**